Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE SUMMARY

Project: NYSD - SUPT. Residence
Pace Project No.: 10366538

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10366538001	**Laundry Room Sink**			

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

SAMPLE ANALYTE COUNT

Project: NYSD - SUPT. Residence
Pace Project No.: 10366538

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366538001	**Laundry Room Sink**	EPA 200.8	WBS	1	PASI-M
10366538002	**Main Level/Kitchen Sink**	EPA 200.8	WBS	1	PASI-M
10366538003	**Lower Level/Bathroom Sink**	EPA 200.8	WBS	1	PASI-M
10366538004	**Upper Level 2 /Bathroom Sink**	EPA 200.8	WBS	1	PASI-M
10366538005	**Upper Level 1 /Bathroom Sink**	EPA 200.8	WBS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

ANALYTICAL RESULTS

Project: NYSD - SUPT. Residence
Pace Project No.: 10366538

Sample: Laundry Room Sink **Lab ID: 10366538001** Collected: 10/07/16 23:05 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	**1.8**	ug/L	0.10	1		10/21/16 18:08	7439-92-1	

Sample: Main Level/Kitchen Sink **Lab ID: 10366538002** Collected: 10/07/16 23:05 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	**5.3**	ug/L	0.10	1		10/21/16 18:10	7439-92-1	

Sample: Lower Level/Bathroom Sink **Lab ID: 10366538003** Collected: 10/07/16 23:07 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	**36.5**	ug/L	0.10	1		10/21/16 18:11	7439-92-1	

Sample: Upper Level 2 /Bathroom Sink **Lab ID: 10366538004** Collected: 10/07/16 23:09 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	**3.1**	ug/L	0.10	1		10/21/16 18:12	7439-92-1	

Sample: Upper Level 1 /Bathroom Sink **Lab ID: 10366538005** Collected: 10/07/16 23:11 Received: 10/14/16 09:45 Matrix: Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW	Analytical Method: EPA 200.8							
Lead	**5.1**	ug/L	0.10	1		10/21/16 18:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
1700 Elm Street - Suite 200
Minneapolis, MN 55414
(612)607-1700

QUALITY CONTROL DATA

Project: NYSD - SUPT. Residence
Pace Project No.: 10366538

QC Batch: 442010 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
Associated Lab Samples: 10366538001, 10366538002, 10366538003, 10366538004, 10366538005

METHOD BLANK: 2407294 Matrix: Water
Associated Lab Samples: 10366538001, 10366538002, 10366538003, 10366538004, 10366538005

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/21/16 17:48	

LABORATORY CONTROL SAMPLE: 2407295

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	98.9	99	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2411863

MS

103665352Tw 0 0 8 30.594 439.36 Tm 1 735 Td (alysi 27 2U.9 (08 Lab Samples:)T65 TtTRI5)T65 TtTRalysi 27